



AALBORG UNIVERSITY  
DENMARK



UNIVERSITY OF  
THE FAROE ISLANDS

# Hvussu verður føroysk elorka grøn í 2030? -sambært ph.d. verkæftlan-

---

Helma Maria Trondheim

Ósvart, 3. novembur 2022



# Innhald

- Innleiðing
- Útbyggingaráetlan fram ímót 2030
- Grøn orka og stabil elveiting
- Samanumtøka

# Innleiðing

Motiváón og føroyska elskipanin


# Motivation

- Verkætlanin er grundað grønu visjónina hjá SEV
- Umhvørvisligir fyrimunir við burðardyggari orku
- At balansera orkuframleiðsluna er ein avbjóðing
- Truplari at tryggja støðufesti við grønum orkukeldum



# Føroya elskipanin

- 7 avbyrgd elnet í ymsum støddum
- Samlaða framleiðslan í 2021 var 424 GWt, harav 38% grøn
- Sløg av orku
  - Olja, vatn, vind, biogas, sól og sjóvarfall
- Goymslir
  - Vatnbyrgingar og battarískipanir




# Útbyggingarætlan

Hvør er best egnaða ætlanin?

# Orkubalansa

- At balansera orkuframleiðsluna er ein avbjóðing
  - Orkukeldurnar eru ikki 100% forsagnar
  - Náttúrlig tíðarbil utan orkutilfeingi
  - Skiftandi árstíðir
- Hvør er best egnaða útbyggingaráætlánin?



# Útbyggingarætlanir

- Elnetini í ávísum oyggjasamfelögum líkjast tí føroyska, t.d. Madeira. Tó er ongin ítøkilig mannagongd, ið vit brúka beinleiðis.
- Útbyggingarætlanir eru ofta bert grundaðar á búskaparligar optimeringar, men hesar eftirhyggjast.
- Hædd má verða tikan fyrir praktiskum viðurskiftum fyrir at hava eina ítøkiliga útbyggingarætlan
- Ein ítøkilig útbyggingarætlan er neyðug um man skal røkka málinum

**Policy constraints**  
 $CO_2$  restrictions & maximum instantaneous inverter-based generation

**System model**  
existing capacities, committed capacities, demand, costs & emissions

**Investment options**  
suitable sites, local resource potential, maximum capacities per site & costs

### Balmorel optimisation

#### Dispatch

- Per hour
- Per plant
- Per connection
- Optimal use of hydro

#### Investments


- Per year
- Capacity
- Location
- Technology type

Simultaneous

Optimal investments

### RoadMap generation

**Criteria**  
Plant sizes  
Cable sizes  
Learning curve  
Practicality



### Balmorel

- #### Dispatch
- Per hour
  - Per plant
  - Per connection
  - Optimal use of hydro


Economics and production

### Validation

#### Economics

#### Production

### Final RoadMap



## Policy constraints

CO<sub>2</sub> restrictions & maximum instantaneous inverter-based generation

## System model

existing capacities, committed capacities, demand, costs & emissions

## Investment options

suitable sites, local resource potential, maximum capacities per site & costs

## Balmorel optimisation

### Dispatch

Per hour  
Per plant  
Per connection  
Optimal use of hydro

### Investments


Per year  
Capacity  
Location  
Technology type

Simultaneous

## Optimal investments

## RoadMap generation

Criteria  
Plant sizes  
Cable sizes  
Learning curve  
Practicality



## Balmorel

Dispatch  
Per hour  
Per plant  
Per connection  
Optimal use of hydro


## Economics and production

### Validation

#### Economics


#### Production

### Final RoadMap



# Úrslit frá optimeringini

## Framleiðslumáttur (MW)




## Vatngóymsla (MWt)



# Úrslit frá optimeringini

## Sensitivitetur á vindmátti (MW)



## Samanumtikið

- Burðardygg orka er búskaparliga besta valið upp til 86-87%
- Stigið frá 96% í 2028 til 100% í 2030 tvífaldar tørvin á goymslu
- Sjóvarfalsorka kann kollvelta útbyggingaráætlini, tí at hon minkar framleiðslumáttin við 18% og goymslutørvin við 75%
- +/- 20% íløgu- og brennievniskostnaður ikki hevur stóra ávirkan á útbyggingina

## Policy constraints

CO<sub>2</sub> restrictions & maximum instantaneous inverter-based generation

## System model

existing capacities, committed capacities, demand, costs & emissions

## Investment options

suitable sites, local resource potential, maximum capacities per site & costs

## Balmorel optimisation

### Dispatch

Per hour  
Per plant  
Per connection  
Optimal use of hydro

### Investments


Per year  
Capacity  
Location  
Technology type

Simultaneous

## Optimal investments

## RoadMap generation

Criteria  
Plant sizes  
Cable sizes  
Learning curve  
Practicality



## Balmorel

Dispatch  
Per hour  
Per plant  
Per connection  
Optimal use of hydro


## Economics and production


## Validation

### Economics

### Production

## Final RoadMap





## Policy constraints

CO<sub>2</sub> restrictions & maximum instantaneous inverter-based generation

## System model

existing capacities, committed capacities, demand, costs & emissions

## Investment options

suitable sites, local resource potential, maximum capacities per site & costs

## Balmorel optimisation

### Dispatch

Per hour  
Per plant  
Per connection  
Optimal use of hydro

### Investments


Per year  
Capacity  
Location  
Technology type

Simultaneous

## Optimal investments

## RoadMap generation

Criteria  
Plant sizes  
Cable sizes  
Learning curve  
Practicality



## Balmorel

Dispatch  
Per hour  
Per plant  
Per connection  
Optimal use of hydro

RoadMap


## Economics and production

### Validation

Economics

Production

### Final RoadMap



## Policy constraints

CO<sub>2</sub> restrictions & maximum instantaneous inverter-based generation

## System model

existing capacities, committed capacities, demand, costs & emissions

## Investment options

suitable sites, local resource potential, maximum capacities per site & costs

## Balmorel optimisation

### Dispatch

Per hour  
Per plant  
Per connection  
Optimal use of hydro

### Investments


Per year  
Capacity  
Location  
Technology type

Simultaneous

## Optimal investments

## RoadMap generation

Criteria  
Plant sizes  
Cable sizes  
Learning curve  
Practicality



## Balmorel

Dispatch  
Per hour  
Per plant  
Per connection  
Optimal use of hydro


## Economics and production

### Validation

#### Economics


#### Production

### Final RoadMap



# Validering av útbyggingarætlan

- Framleiðslan er optimera í Balmorel, útbyggingin er føstløgd
- Framleiðslan í 2030 skal verða 100% burðardygg
- Búskaparliga skal útbyggingarætlanin líkjast tí optimalu loysnini



## Policy constraints

CO<sub>2</sub> restrictions & maximum instantaneous inverter-based generation

## System model

existing capacities, committed capacities, demand, costs & emissions

## Investment options

suitable sites, local resource potential, maximum capacities per site & costs

## Balmorel optimisation

### Dispatch

Per hour  
Per plant  
Per connection  
Optimal use of hydro

### Investments


Per year  
Capacity  
Location  
Technology type

Simultaneous

## Optimal investments

## RoadMap generation

Criteria  
Plant sizes  
Cable sizes  
Learning curve  
Practicality



## Balmorel

Dispatch  
Per hour  
Per plant  
Per connection  
Optimal use of hydro


## Economics and production

### Validation


#### Economics

#### Production

### Final RoadMap



# Útbyggingaráætlanin




# Støðufesti

Hvussu tryggja vit støðufesti?



# Støðufesti á elnetinum

- Olju- og vatnverkini tryggja støðufesti á elnetinum í dag
- Øðrvísi elframleiðsla
  - Avmarkaðar og veðurstýrdar orkukeldur
  - Óstøðugar orkukeldur
  - Avbyrgt elnet
  - Inverter-basera framleiðsla
- Hvussu tryggja vit støðufesti?



**Elverkið í Botni**  
**3 MW**



**Porkerishagin**  
**6,3 MW**



**Vágsverkið**  
**14 MW**




**Sólpanelini í Sumba**  
**0,3 MW**





# Dømi úr Suduroy



Samanumtøka

# Samaumtøka

- Niðurstøður
  - Verandi m átar at gera útbyggingarætlanir kunnu ikki altíð lætt ítökilig gerast og tí er neyðugt við einum nýggjum máta
  - Optimala orkusamansetningin er funnin og ávirkanin av ymsum kostnaðum og tøknum er identifiserað
  - Ein útbyggingarætlan framímóti 2030 er gjørd
  - Tað er neyðugt við øðrvísi m átum at tryggja støðufesti
- Arbeiði, ið skal gerast framyvir
  - Útbyggingarætlanin má dagførast regluliga
  - Støðufesti má kannast nærri bæði í Suðri og á meginøkinum
  - Meginøkið skal parametriserast og validerast betri



UNIVERSITY  
OF  
THE FAROE ISLANDS

Takk fyri